

Walk-in cold rooms

Jonathan Bain

ENTR Lot 1 3rd Stakeholder Meeting
Brussels, Belgium, October 25th 2010

A study being conducted for DG ENTR by BIO Intelligence Service



10:00 – 10:20	Welcome, explanation of the meeting structure and “Tour de table”
10:20 – 10:30	Short introduction to the Ecodesign Directive
10:30 – 10:40	Horizontal session: Progress update
10:40 – 11:30	Product focus: Walk-in cold rooms
11:30 – 11:50	COFFEE BREAK
11:50 – 12:40	Product focus: Service cabinets
12:40 – 13:30	Product focus: Blast cabinets
13:30 – 14:20	LUNCH BREAK
14:20 – 15:10	Product focus: Remote condensing units
15:10 – 15:40	Product focus: Chillers
15:40 – 16:00	COFFEE BREAK
16:00 – 16:40	Horizontal session: Refrigeration systems and refrigerants
16:40 – 17:30	Conclusions, next actions to be taken and AOB

Product description

- A walk-in cold room is a refrigerated space, large enough to walk into, maintained at a temperature lower than ambient by a refrigerating system temperature.
- Walk-in cold provide refrigerated storage for a variety of items (foodstuff).
- The rooms are constructed from self supporting, pre-fabricated panels.
- They may exist solely as refrigerators or freezers, or a refrigerator-freezer combination.



Functional Unit

- One m³ of net volume at storage temperature

➤ **Exclusions**

- pharmaceutical storage or other application using a double refrigeration system;
- above 400m³ in size;
- incorporating loading bays designed to provide access to vehicles;
- forming part of a building, having load-bearing walls or supporting the roof of a building; and
- constructed as a stand-alone external building.

Year	Estimated sales forecast *	Estimated stock forecast *
2006	87,926	1,491,948
2007	88,052	1,507,074
2008	88,289	1,521,659
2009	89,112	1,543,838
2012	91,059	1,578,022
2020	99,230	1,690,370
2025	103,522	1,785,024

*Extrapolation of figures provided by stakeholders

- UK MTP data extrapolated to EU
- Cross-checked against BSRIA data for France
- CAGR (2010-2014): 0.93%

Technology	(%)
Small	67
Medium	31
Large	2
Refrigerators	69
Freezers	31
Refrigerators-freezers	1
Factory-built (packaged)	30
Tailor-made	60
Integral	20
Monoblock	25
Remote condensing unit	40
Remote plant	15

Size	Operation temperature	Design
Small (up to 20m3)	Refrigerators	Factory-built (packaged)
		Tailor-made
	Freezer	Factory-built (packaged)
		Tailor-made
	Refrigerator / freezer	Factory-built (packaged)
		Tailor-made
Medium (20m3 to 100m3)	Refrigerators	Factory-built (packaged)
		Tailor-made
	Freezer	Factory-built (packaged)
		Tailor-made
	Refrigerator / freezer	Factory-built (packaged)
		Tailor-made
Large (100m3 to 400m3)	Refrigerators	Factory-built (packaged)
		Tailor-made
	Freezer	Factory-built (packaged)
		Tailor-made
	Refrigerator / freezer	Factory-built (packaged)
		Tailor-made

- **US DOE** test standard currently separates shell (envelope) and refrigeration system; adapting the **ANSI/AHRI 1250:2008** standard
- Computer modeling
- **EN ISO 23953:2005** for factory-built?

- Food safety and construction standards
 - **EN 1672 :1997**: Food processing machinery hygiene requirements
 - **EN ISO 14159:2002**: Hygiene requirements
 - **DE VDMA 11499**: Operation and use of refrigerated display cabinets
 - **US NSF/ANSI 7:2009**: minimum food protection and sanitation requirements

- No MEPS or voluntary agreements
- Legislation relates to components: **US California Energy Commission** requirements
- **ETAG 021** – only refers to prefabricated equipments:
 - Thermal performance
 - Air permeability
 - Water vapour permeability
- These do not deal with energy performance, but with the function within kitchens for food safety reasons:
 - French commercial food preparation hygiene requirements law of 29/09/1997
 - UK Department of Health Guidelines
 - Austrian Hygiene Certificate Guideline


Base Case weighting

- AEC based on UK MTP assumptions
- Estimated average size of 25m³

Size	Operation temperature	MTP estimated market proportion	MTP estimated average cooling load (kW)	MTP estimated average COP	MTP estimated average AEC of sub-categories (kWh/year)	Estimated average net internal volume (m ³)
Small (up to 20m ³)	Chiller	44.49%	1.4	1.84	6,665	12
	Freezer	22.54%	1.3	1.32	8,627	12
Medium (20m ³ to 100m ³)	Chiller	23.36%	4.5	2.41	16,357	40
	Freezer	8.10%	4.58	1.47	27,293	40
Large (100m ³ to 400m ³)	Chiller	1.13%	18	2.66	59,278	300
	Freezer	0.48%	19	1.47	113,224	300

Based on a partial Bill of Material obtained for a 25m³ envelope + extrapolated Bill of Materials for a monoblock unit of correct specifications to supply the 25m³ cold room.

Product characteristics	Sub-Base Case (estimated)	Weighted Base Case (abstract product)
Design:	Monoblock, factory-made	-
Functional unit:	m ³ net volume at +2°C	m ³ net volume at storage temperature
Net internal volume [m ³]:	25	25
AEC [kWh/year]:	10,570	12,155
Use pattern:	8760 hours per year	8760 hours per year
Price (ex VAT) [€]:	8,800	8,800
Lifetime [years]:	10	10
Shipping volume [m ³]:	15	15
Weight of product [kg]:	1000	1000
Refrigerant:	R404a	R404a
Refrigerant charge [g]:	2,400	3,000
Refrigerant leakage [% per annum]:	5	9
Refrigerant dumped at EoL [%]:	5	5




Environmental impacts

Total Energy (GER):

5901.34 MJ / m³ at storage temperature / year, of which the use phase represents **94%**

Direct GWP represents about **15%** of the TEWI



Saving potential of **35% AEC**
is estimated for BAT

Parameter	BAT
Design	Monoblock, factory-built
Functional unit:	m ³ net volume at +2°C
Net internal volume [m ³]:	25
AEC[kWh/year]:	6,870
Use pattern:	8760 hours per year
Price [€]:	10,560
Lifetime [years]:	12
Weight of product [kg]:	<i>TO BE COMPLETED</i>
Refrigerant:	R134a for HT / R410a for LT
Refrigerant charge [g]:	2,040
Refrigerant leakage [% per annum]:	5
Type of compressor:	Hermetic reciprocating
Power input of compressor [W]:	<i>TO BE COMPLETED</i>
Condenser cooling:	Air-cooled
Performance [kWh/m ³ at 2°C/year]:	275
Cooling capacity [kW]:	3.485
Power input [kW]:	1.42

Product	AEC (kWh /year)
Weighted Base Case	12,155
Weighted BAT	7,901

	Applicability (years)	Market penetration (%)	Savings (% TEC)	Increase in price of product (€)	Priority
Strip door curtains	Now	N.A.	13	60	1
Auto door closer	Now	N.A.	12	111	2
PSC evaporator fan	Now	N.A.	10	100	3
ECM evaporator fan	Now	N.A.	13	150	4
High efficiency fan blades	Now	N.A.	3	50	5
Insulation thickness	Now	N.A.	15	250	6
ECM condenser fan	Now	N.A.	3	60	7
High efficiency LED light bulbs	Now	N.A.	4	200	8
R134a to replace R404a at HT, and R410a to replace R404a at LT	Now	N.A.	0**	0	9
Floating head pressure (plus electronic expansion valve)	Now	1	8	150	10
Ambient subcooling	Now	N.A.	4	170	11
High efficiency compressor*	Now	N.A.	5	200	12
Anti-condensation control	Now	N.A.	3	370	13
Defrost control	Now	0	5 to 10***	N.A.	6
BNAT					
VSD compressor	2 to 3	N.A.	15	N.A.	1
ECM compressor	2 to 3	N.A.	4	N.A.	2
Hot gas defrost	2 to 3	N.A.	4***	81	3
Hot gas anti-condensation	2 to 3	N.A.	13***	323	4
Fan motor control	2 to 3	0	3	N.A.	5

*Selected from technologies related to the component

**The benefit of this improvement is also the lower GWP of the refrigerant


***Applicable to low temperature only

N.A.: Data not available

Note: Savings are not additive.

Priority based on cost increase, energy saving potential and applicability

Primary Energy Consumption and LCC



Options	
1	Strip door curtains
2	Auto door closer
3	PSC evaporator fan
4	ECM evaporator fan
5	High efficiency fan blades
6	Insulation thickness
7	ECM condenser fan
8	R134a to replace R404a at HT, and R410a to replace R404a at LT
9	High efficiency LED light bulbs
10	Floating head pressure (plus electronic expansion valve)
11	Ambient subcooling
12	High efficiency compressor

Scenario A: includes options 1 to 6

Scenario B: includes options 1 to 12

	Energy consumption HT (kWh)	Savings HT	Product price HT (€)
Weighted Base Case	12,155	-	8,800
LLCC = BAT = Scenario B	4,862	-60%	10,431
Real weighted BAT	7,901	-35%	10,560

The “best” walk-in cold rooms within next 5 years could achieve energy savings of up to approximately 80% using the following:

Refrigerant:	R134a; or R410a; or R744; or R717
Compressor:	VSD ECM
Expansion device:	EEV
Evaporator:	ECM with efficient fan blades and improved heat exchanger
Condenser:	ECM with efficient fan blades and improved heat exchanger
Defrost :	Hot gas, controlled
Anti-condensation heaters :	Hot gas, controlled
Lighting:	LED
Insulation:	+25% thickness PUR
Other:	Strip door curtain and auto door closer; floating head pressure and ambient subcooling

	Estimated average AEC (kWh)
Weighted Base Case	12,155
Weighted BAT	7,901
Weighted BNAT	2,431

Size	Operation temp.	Average volume (m ³)	Average Base Case AEC (kWh /year)	Average real BAT AEC (kWh /year)	Average BNAT AEC (kWh /year)	Base Case EEI	LLCC EEI	BNAT EEI
Small (up to 20m ³)	Chiller	12	6,665	4,332	1,333	3.04	1.22	0.61
	Freezer	12	8,627	5,608	1,725	3.94	1.58	0.79
Medium (20m ³ to 100m ³)	Chiller	40	16,357	10,632	3,271	2.24	0.90	0.45
	Freezer	40	27,293	17,740	5,459	3.74	1.50	0.75
Large (100m ³ to 400m ³)	Chiller	300	59,278	38,531	11,856	1.08	0.43	0.22
	Freezer	300	113,224	73,596	22,645	2.07	0.83	0.41

Assumptions:

- Short-term MEPS: LLCC
- Long-term MEPS: BNAT
- Improvement potentials applied to all categories in the same proportion

Size	Location of the condensing unit	Short-term MEPS based on LLCC (max. EEI)	Long-term MEPS based on BNAT (max. EEI)
Small (up to 20m ³)	Refrigerator	1.22	0.61
	Freezer	1.58	0.79
Medium (20m ³ to 100m ³)	Refrigerator	0.90	0.45
	Freezer	1.50	0.75

- The MEPS would be measured under the following:
 - It is proposed that Total Electrical Energy Consumption could be measured under EN ISO 23953:2005.
 - Net Volume: the product of the internal dimensions.
 - Adjustment factor for refrigerator-freezers:
 - $AV = \text{volume of refrigeration compartment in litres} + (1.33 \times \text{volume of freezing compartment in litres})$.
 - If energy consumption of freezing per unit volume is 1.5 times that of refrigeration adjustment allows for approximately 75% internal volume to be freezing storage.

- The following minimum requirements are proposed:
 - **automatic door closers;**
 - **strip door curtains** or other method of minimising infiltration;
 - minimum heat resistance **insulation;**
 - minimum heat resistance **floor insulation for freezers;**
 - for **evaporator fan motors:** ECMs or 3-phase motors;
 - for **condenser fan motors:** ECMs or 3-phase motors.
- It is estimated that this will enable a reduction in consumption of an average of approximately 30%.
- Further requirements, based on the US CEC (or other improvement options) could also be set, including for example:
 - **efficient lighting;**
 - **Double- or triple-pane glass** with either heat-reflective treated glass or gas fill;
 - maximum total **door rail, glass, and frame heater power draw;** or with anti-sweat heat controls, above this, the controls reduce energy use in a quantity corresponding to the relative humidity in the air outside the door or to the condensation on the inner glass pane.
- **Test standards to measure performance of components required.**



Alternative approaches

- **Installation requirements/guidelines**
- **Information requirements**
- **Generic requirements**
- **Voluntary initiative (benchmarks)**
- **Energy labelling**